

Corrigendum to Bid No. GEM/2025/B/6277475 dated 29.05.2025

**(Comprehensive Maintenance Contract of the existing Pre-fabricated BSL-3 & ABSL-3 facilities
at BRIC-ILS)**

Clause/ terms & conditions originally mentioned in the bid	Amendment Done																																
Firms to be necessarily ISO 9000, ISO14001, 13465 certified.	Firms to be necessarily ISO 9000, ISO14001, 13485 certified.																																
Firm should be WHO-GMP or equivalent Certified for the Biosafety labs.	The bidder should have international / national accreditation for maintenance and services of Biosafety labs (BSL-3 & ABSL-3)as per DBT-RCGM or any other equivalent approved guideline by the Government																																
CMC Proposal for existing BSL & ABSL III facility for 1 year extendible annually for up to a max 3 years - Start Date 15.06.2025	CMC Proposal for existing BSL-3 & ABSL -3 facility for 1 year extendible annually for up to a max 3 years - Start Date 15.07.2025																																
Newly Added Clause/ point	<p>As both the facilities have the following Critical equipment, the bidder should assure us for proper service and repair of these equipment using original spares from the OEM's mentioned as and when required. Preference will be given to bidders having authorization of the following OEMs for sales & or service. An indemnity bond equal to one quarter (3 months) of the CMC quoted value will be submitted by the bidder within 15 days of placement of order as a guarantee for efficiency service and maintenance of the facility. The total downtime of an equipment or the facility should not be more than 20 days in a year. Otherwise a penalty of Rs. 1000/- per day will be deducted from the CMC bill. However, the ILS BSL-3 committee or the competent authority will assess and take appropriate decision of the down time and penalty charges.</p> <table><tr><th>S/No</th><th>Name of Instrument</th><th>Company Name</th><th>Model No</th></tr><tr><td>1</td><td>Chiller</td><td>Blue star</td><td>XAC2YS-080AR2</td></tr><tr><td>2</td><td>AHU</td><td>Zeco Aircon Limited</td><td>ZDS-30 , ZDS 50 & ZDS 60</td></tr><tr><td>3</td><td>BMS</td><td>Siemens</td><td></td></tr><tr><td>4</td><td>Vfd</td><td>Danfoss</td><td></td></tr><tr><td>5</td><td>Autoclave</td><td>Machin Fabrik</td><td></td></tr><tr><td>6</td><td>Biosafety Cabinet Class 2 type 2</td><td>Microflit</td><td></td></tr><tr><td>7</td><td>L/T Panel</td><td>Shivalic & KEPL</td><td></td></tr></table>	S/No	Name of Instrument	Company Name	Model No	1	Chiller	Blue star	XAC2YS-080AR2	2	AHU	Zeco Aircon Limited	ZDS-30 , ZDS 50 & ZDS 60	3	BMS	Siemens		4	Vfd	Danfoss		5	Autoclave	Machin Fabrik		6	Biosafety Cabinet Class 2 type 2	Microflit		7	L/T Panel	Shivalic & KEPL	
S/No	Name of Instrument	Company Name	Model No																														
1	Chiller	Blue star	XAC2YS-080AR2																														
2	AHU	Zeco Aircon Limited	ZDS-30 , ZDS 50 & ZDS 60																														
3	BMS	Siemens																															
4	Vfd	Danfoss																															
5	Autoclave	Machin Fabrik																															
6	Biosafety Cabinet Class 2 type 2	Microflit																															
7	L/T Panel	Shivalic & KEPL																															
Bid End Date: 23.06.2025. 17.00 hrs	New Bid End Date: 01.07.2025. 17.00 hrs																																